



GOVT OF KARNATAKA
DEPARTMENT OF HEALTH AND FAMILY WELFARE
TALUK HEALTH OFFICE, KUDLIGI/KOTTURU.
KOTTUR TQ VIJAYANAGARA DIST - 583136
Email: thokudligitho22@gmail.com

NO: THO/KDL/ 21-/2025-26

DATE: 20/06/2025


HEALTH AND SANITARY CERTIFICATE


This is to certify that the Premises of Delhi World School, Kotturu, located at near Hyalya Hagaribommanahalli road, The Health department of Koturu Taluk on 20-06-2025. Upon Inspection the School has been found to be complaint with the required health and sanitation standards as prescribed by the Health and Family Welfare department, Government of Karnataka.

THE SCHOOL HAS:-

- Adequate and clean drinking water facilities.
- Proper sanitation and waste disposal Systems.
- Well-maintained toilets and handwashing areas.
- A hygienic environment suitable for children.

This certificate is Issued and remains valid for the academic year 2025-26.


TALUK HEALTH OFFICER
KUDLIGI/KOTTURU


PRINCIPAL
DELHI WORLD SCHOOL
34-8-536, Near Hyalya,
Hagaribommanahalli Road,
Kottur-583134. Vijayanagara (Dt)





GOVT OF KARNATAKA
DEPARTMENT OF HEALTH AND FAMILY WELFARE
TALUK HEALTH OFFICE, KUDLIGI/KOTTURU.
KOTTUR TO VIJAYANAGARA DIST-583136
Email: thokudligitho22@gmail.com

NO: THO/KDL/4/2025-26

DATE: 20/06/2025

HEALTH AND SANITARY CERTIFICATE

This is to certify that the Premises of Delhi World School.Kotturu, located at near Hyalya Hagaribommanahalli road, The Health department of Kotturu Taluk on 20-06-2025. Upon Inspection the School has been found to be complaint with the required health and sanitation standards as prescribed by the Health and Family Welfare department, Government of Karnataka.

THE SCHOOL HAS:-

- Adequate and clean drinking water facilities.
- Proper sanitation and waste disposal Systems.
- Well-maintained toilets and hand washing areas.
- A hygienic environment suitable for children.

This certificate is Issued on the basic of water sample test report submitted by the school Vide no GEMS-LD/TF/23/01 and date 20-06-2025 remains valid for the academic year 2025-26.This certificate

TALUK HEALTH OFFICER
KUDLIGI/KOTTURE



COMPARED WITH ORIGINAL
& TRUE COPY ATTESTED BY ME

K. MUGANNA
K. MUGANNA
NOTARY, KUDLIGI 20/8/25

[Signature]
PRINCIPAL
DELHI WORLD SCHOOL
34-8-536, Near Hyalya,
Hagaribommanahalli Road,
Kottur-583134. Vijayanagara (D





GLOBAL ENVIRONMENT & MINING SERVICES

(Consulting Engineers, Mine designers, Geologist & Surveyors)

3rd Main Road, Basaveswara Badavane,

HOSAPETE - 583201, Dist., Vijayanagara (Karnataka)

Ph : +918394 355369

e-mail : gems_hpt@yahoo.com

Website : www.globalmining.in

12

GEMS-LD/TF/23/01

TEST REPORT OF WATER QUALITY DATA

1. Name of the Customer/Address : **Delhi World School**
Halya Road, Kotturu,
Kotturu Taluk, Vijayanagara Dist.,
Karnataka State.
2. Customer Reference : Sample collected Date: 19.06.2025 (by Hand)
3. Sample collected by : (Submitted Sample)
4. Sample Received : 19.06.2025
5. Date of Analysis : 19.06.2025
6. Date of Completion : 20.06.2025
7. Report Issued Date : 20.06.2025
8. Sample Type : **Filter Water**
9. Discipline : **Chemical**
10. Group : **Water**
11. Sample Quantity : Each Sample 2.0 Lts.
12. Environmental Condition : **Good**
13. Sample Method : **Not Applicable**
14. Sample Code : **156**
15. Report Number : **GEMS/FW/2025-2026/143**

Results

Sl. No	Parameters	Protocol	Unit	Results	Standards as per IS: 10500:2012	
					Acceptable Limits	Permissible Limit in the Absence of Alternate Source
PHYSICAL						
1	pH	APHA 24th Edition 4500 H +B: 2023	-	6.79	6.5 to 8.5	NR
2	Conductivity	APHA 24th Edition 2510 B : 2023	µS/cm	290	-	-
3	Total Dissolved Solids	APHA 24th Edition 2540 C: 2023	mg/L	174	500max	2000 max
4	Turbidity (NTU)	APHA 24th Edition 2130 B: 2023	NTU	0.1	1 max	5max
5	Total Suspended Solids	APHA 24th Edition 2540 D: 2023	mg/L	<1.0	-	-
CHEMICAL						
6	Sulphate as SO4	APHA 24th Edition 4500 SO4 E: 2023	mg/L	18.41	200max	400max
7	Phosphorus as P	APHA 24th Edition 4500 P D: 2023	mg/L	BDL	-	-
8	Sodium as Na	APHA 24th Edition 3500 Na B : 2023	mg/L	6.12	-	-
9	Potassium as K	APHA 24th Edition 3500 K B : 2023	mg/L	0.0	-	-
10	Calcium as Ca	APHA 24th Edition 3500 Ca B : 2023	mg/L	19.0	75max	200max
11	Magnesium as Mg	APHA 24th Edition 3500 Mg B : 2023	mg/L	23.08	30max	100max
12	Total Hardness as CaCO3	APHA 24th Edition 2340 C : 2023	mg/L	142.5	200max	600max
13	Chloride as Cl	APHA 24th Edition 4500 Cl B: 2023	mg/L	75.49	250max	1000 max
14	Fluoride as F	APHA 24th Editin 4500 F D : 2023	mg/L	0.57	1 max	1.5 max
15	Nitrate Nitrogen as NO3	APHA 24th Edition 4500 NO3 E: 2023	mg/L	3.52	45 max	NR max
16	Total Alkalinty as CaCO3	APHA 24th Edition 2320 B : 2023	mg/L	50.0	200 max	600 max
17	Total Iron as Fe	APHA 24th Editon 3500 Fe B : 2023	mg/L	BDL	0.30 max	NR
TRACE METALS						
18	Nickel as Ni	APHA 24th Edition 3111 B: 2023	mg/L	BDL	0.02 max	NR
19	Manganese as Mn	APHA 24th Edition 3111 B: 2023	mg/L	BDL	0.10 max	0.30 max
20	Copper as Cu	APIIA 24th Edition 3111 B: 2023	mg/L	BDL	0.05 max	1.50 max
21	Zinc as Zn	APIIA 24th Edition 3111 B: 2023	mg/L	BDL	5 max	15 max
22	Lead as Pb	APHA 24th Edition 3111 B : 2023	mg/L	BDL	0.01 max	NR

Note:

1. The result listed refers only to the tested samples & applicable parameters. Endorsement of products is neither inferred nor implied.
2. Water Samples will be destroyed after 70 days, Minerals 3 Months, Filter papers & Thinblades After analysis Discard 7 days.
3. This report is not to be reproduced wholly or in part & cannot be used as evidence in the Court of law & should not be used for legal purposes.
4. Total liability of our laboratory is limited to the Invoice amount. Any dispute arising out of this report is subject to local jurisdiction only.
5. Recognized by Ministry of Environment, Forest and Climate Change for Laboratory
6. Recognized by Government of Karnataka, Maharashtra, Goa for DGPS survey

PRINCIPAL

34-8-536, Near Hyalya,

Hagaribommanahalli Road,

Vijayanagara - 583201



Scanned with OKEN Scanner



GLOBAL ENVIRONMENT & MINING SERVICES

(Consulting Engineers, Mine designers, Geologist & Surveyors)

3rd Main Road, Basaveswara Badavane,

HOSAPETE - 583201, Dist., Vijayanagara (Karnataka)

Ph : +918394 355369

e-mail : gems_hpt@yahoo.com

Website : www.globalmining.in

GEMS/ FW/2025-26/143

23	Chromium as Cr	APHA 24th Edition 3111Cr B : 2023	mg/L	BDL	0.05 max	NR
Microbiological Parameters						
24	E-Coli	IS: 1622: 1981	MPN/10 0ml	Absent	Shall not be detectable in any 100 ml	-
25	Total Coliforms	IS: 1622: 1981	MPN/10 0ml	Absent	Shall not be detectable in any 100 ml	-

Note: Raw Water (Sample not drawn by us)

Total Coliforms are Absent in the Water Sample

BDL: Below Detectable Limit

Ag: Agreeable

NR: No Relaxation

RA: Reaffirmed

End of Report

T. Chandana

Analysed By
T. Chandana
Chemist

Authorised Signatory
K. Ramakrishna Reddy
Technical Manager



PRINCIPAL

DELHI WORLD SCHOOL
34-8-536, Near Hyalya,
Hagaribommanahalli Road,
Kottur-583134. Vijayanagara (Dt)

Note:

- The result listed refers only to the tested samples & applicable parameters. Endorsement of products is neither inferred nor implied.
- Water Samples will be destroyed after 7 Days, Minerals 3 Months, Filter papers & Thimbles After analysis Discard 7 days.
- This report is not to be reproduced wholly or in part & cannot be used as evidence in the Court of law & should not use any advertising media without special permission in writing.
- Total liability of our laboratory is limited to the Invoice amount. Any dispute arising out of this report is subject to Hosapete jurisdiction only.
- Recognized by Ministry of Environment, Forest and Climate Change for Laboratory
- Recognized by Government of Karnataka, Maharashtra, Goa for DGPS survey

